

DIAGNOSTIC FOR POORLY TUNED CONTROL LOOPS

BACKGROUND OF THE INVENTION

Field of the Invention

- (001) The present invention relates to process control systems and, more particularly, to automatic detection of oscillation caused by poorly tuned control.

Description of the Prior Art

- (002) Large complex manufacturing systems, such as pulp and paper mills or chemical petroleum plant, contain often thousands of control loops. The performance of some of these loops is critical to the quality and the uniformity of the final product. In such a large system, variability is introduced in a variety of ways; non-linearity of valves or sensors, controller tuning, process upsets, disturbances, loop interactions, operator interactions and these are only a few of them. Determining what particular problem is affecting the control performance is a non-trivial matter. This can be addressed in two steps: the first step is to detect poorly performing loops and then, in the second step, determine the reason of such poor performance for each loop identified. Or, equivalently, quantification of control loop performance using performance indices, followed by diagnosis to determine what causes the poor performance.

- (003) In the article "Assessment of control loop performance", by T. J. Harris, Can. J. Chem. Eng., 67, pp. 856-861, 1989, Harris proposed comparing the observed level of variance of a controlled variable to the minimum variance controller. In essence, the proposed method detects whether or not there exists an excessive variability; therefore one can categorize loops, into poorly performing loops and acceptable performing loops. The result of the assessment depends on the accuracy of the process time delay, data sampling rate and on how the minimum variance benchmark is estimated. This method does not diagnose directly the cause of the poor performance. Increase in the level of variability is used to detect malfunctioning control loop in US. Patent 4, 885,676, US Patent 5, 249,119 and, more recently in US Patent 6,298,454. The drawback of this approach is that the results are affected by internal process upsets and the lack of diagnostic engine to determine specifically

what causes poor performance. The interaction of operators may have a great impact on control loop performance. To resolve this issue, R. Spring in US Patent 5,796,606 proposed to monitor continuously all loops, how often they are in manual mode, and which loops are frequently in alarm. He also proposed to determine recursively certain statistical parameters. The monitoring system resides inside the distributed control system (DCS). This adds more load to the DCS system, and the recursive calculations may be biased due to any loop upset.

(004) In a large industrial plant, poor performance is often due to the large number of loops involved and the lack of personnel available to perform the tuning. Many controllers run with default settings that do not optimize loop performance. In other cases, the tuning is done based on the common sense of operators, which can be a misleading practice. Degradations in control performance due, principally, to tuning problems are not extensively addressed in the literature. Most studies are dedicated to proportional, derivative and integral control loops and how to self tune those parameters as done in WO98/12611. On the other hand, detection of poor performance due to a non-linear phenomenon such as actuator or sensor malfunctioning is the subject of many articles in the literature. In the article "Diagnosis and characterization of oscillations in process control loops", by A. Horch, A. J. Isaksson and K. Forsman, Control Systems, 161-165, 2000, it is proposed to use the cross-correlation between the control output and the process variable. Their approach states that, in the presence of stiction, the cross-correlation is null at the zero lag. This method addresses only the case of non-linearity caused by stiction. In practice, valves may be subject to stiction or backlash and, more often, to a combination of the two. The problem of actuator failure is addressed in US Patent 5,838,561. In this Patent, the diagnostic of actuator malfunctioning is based on the use of a probability distribution of the deviation error. The reliability of the diagnostic depends on having a large data set, and can be affected by loop upsets. However, this Patent addresses in a very efficient way the problem of poor performance due to loop interactions.

SUMMARY OF THE INVENTION

- (005) It is an object of the present invention to diagnose control loops to determine whether control loop error is due to tuning or control loop component failure. Furthermore, it is an object of the invention to quantify such determination so as to be able to determine whether a corrective response is necessary.
- (006) A method has been developed to perform an automatic diagnosis for the poor performance, and to determine whether or not the malfunctioning is caused principally by a poor adjustment of the controller tuning parameters. The method makes use of the fact that a poorly tuned control loop amplifies disturbances in a narrow frequency range around the so-called resonant frequency. The diagnostic method is based on a comparison between the calculated power spectral density of the control error and an analytical representation for a poorly tuned loop with a similar resonant frequency.
- (007) A diagnostic method determines automatically whether or not excess variability in a feedback control loop is due, mainly, to poor selection of controller tuning parameters. The power spectral density of the control error, or of the controlled variable, is calculated. Its characteristics are used to derive an analytical representation of a poorly tuned control loop whose resonant frequency and amplification at that frequency matches those calculated for the actual control loop. The diagnostic is based on the ability of the analytical representation to predict the actual power spectral density of the control error, or of the controlled variable, over the entire frequency range excluding frequencies close to zero where the power spectrum density is likely to be poorly estimated.
- (008) The invention also provides a diagnostic apparatus for analyzing control loops, comprising means for recording an error signal between a set-point value and a detected process value, means for determining the power spectrum of the error signal, means for determining a best fit analytical function describing the power spectrum associated with the error signal and means for calculating the difference between the best fit analytical function and the power spectrum, in order to output a diagnostic value.

(009) The invention provides a software product for performing the method of diagnosis of control loops according to the method of the present invention.

DESCRIPTION OF THE DRAWINGS

(0010) **FIG. 1** is a block diagram of a process control loop that is representative of many industrial control loops. The control action generates an output control signal, $CO(t)$, based on a deviation error signal, $ER(t)$, between the set-point, $SP(t)$, and a measured process variable, $PV(t)$. The control signal is then applied to an actuator which translates that electrical signal to a physical action (e.g., opening a valve). A sensor is used to measure the process variable, $PV(t)$.

(0011) **FIG. 2** illustrates the resonance phenomenon in the power spectrum of a poorly tuned control loop. It occurs in a relatively narrow frequency range, at the so-called resonant frequency and to a lesser extent at the surrounding frequencies.

(0012) **FIG. 3** illustrates the type of oscillations caused by an equipment failure; there is a fundamental frequency at f_0 , accompanied by harmonics nf_0 at equidistant intervals of f_0 .

(0013) **FIG. 4** Output response for a level control loop where oscillations are caused by a mal-tuned control.

(0014) **FIG. 5** Power spectrum densities, $\Gamma_M(f)$ and $\Gamma(f)$, for the level control loop of Figure 4. It can be seen that $\Gamma_M(f)$ is a good approximation of $\Gamma(f)$, indicating that the oscillations are caused by the controller.

(0015) **FIG. 6** Output response for a pressure control loop, with a stiction level of 14% causing loop to oscillate.

(0016) **FIG. 7** Power spectrum densities, $\Gamma_M(f)$ and $\Gamma(f)$, for the pressure control loop of Figure 6. It can be seen that $\Gamma_M(f)$ is not an approximation of $\Gamma(f)$. The approximation does not include the high frequency components caused by harmonics induced by the stiction. Therefore, the oscillations are not caused by the controller.

(0017) **FIG. 8** Output response for a temperature control loop, with a backlash level of 7% causing the loop to oscillate.

- (0018) **FIG. 9** Power spectrum densities, $\Gamma_M(f)$ and $\Gamma(f)$, for the temperature control loop of Figure 8. It can be seen that $\Gamma_M(f)$ is not an approximation of $\Gamma(f)$.
- (0019) **FIG. 10** is a block diagram of apparatus used according to the present invention for control loop oscillation diagnostic purposes
- (0020) **FIG. 11** is a block diagram of a control loop diagnostic method according to the present invention

DETAILED DESCRIPTION OF THE INVENTION

- (0021) There are many reasons for degradations in control loop performance. Some of them are attributed to inaccurate sensor readings due to bias, or to actuators that are not responding properly to control signals, due to non-linear phenomena such as backlash or stiction. Such equipment failure may results in a limit cycle, due to the controller's inability to position the valve to maintain a set-point, Weldon A. D. et al., "Control valves- The key component in managing process variability. *Tappi Journal*, 80 (8) 71-74 (1997) ".
- (0022) Degradations in control performance might also be due to poor control tuning, or to interactions with defective loops. Poor tuning can also result in a loop oscillating. Oscillations have an impact on product uniformity, and can cause increased energy consumption and waste of raw material. A recent paper by Clarke et al. "Sensor, actuator, and loop validation. *IEEE Control Systems Magazine*, 39-45, Aug (1995)" showed that, by eliminating oscillations in control loops, a 6% saving in the steam consumption of a batch temperature controlled process was possible.
- (0023) As mentioned before, there are many reasons for a control loop to oscillate. The main ones are: oscillations due to an actuator or sensor non-linearity, a loop oscillating because of its interaction with another oscillating loop, or oscillation caused by a mal-tuned controller. It is of interest to localise the source of oscillations, and then take the appropriate action. Knowledge of the presence of oscillations in control loops may be obtained using, for example, discrete fast Fourier transforms.
- (0024) To study the source of oscillation, we consider the control loop of Figure 1. In what follows, we assume that the cause of the oscillations is internal to the control

loop, such that oscillations are either due to a control tuning problem or to an actuator/sensor problem. Detection of an external oscillation is addressed in the US Patent 5,838,561. The method we are about to describe will permit to determine whether the oscillations are due to a control tuning problem. . The analysis is carried out using the power spectrum density of the deviation error signal. Therefore, we assume that the estimation method of the spectrum is reliable and not subject to any aliasing. In trying to determine the sources of oscillation for a given control loop, we consider the following two situations: 1) actuator and sensor having linear characteristics, as a sign of good functioning equipment. In this case, the control loop is linear and can be represented by a linear transfer function. 2) actuator or sensor having non-linear behavior as a result of equipment failure. In that case we consider the Describing Function method, Cook P. A., "Nonlinear dynamic systems. Prentice-Hall Inc, 1986", to analyse oscillations in that loop.

(0025) **Case 1, Linear relationships:** because of the presence of oscillations in the control loop of Figure 1, the transfer functions between SP(s) and PV(s), or between e(s) and PV(s) is of second-order or higher. A second order model, such as the one obtained using the approach described by Shamash Y. in " Linear system reduction using Padé approximation to allow retention of dominant modes, Int. J. Control: 21 (2) 257-272, 1975" is usually adequate to approximate the dynamics of that loop. In this case we can write

$$\begin{aligned} ER &= SP - PV, \\ \Gamma(s) &= \frac{ER(s)}{d(s)} \text{ and} \\ \Gamma_M(s) &= \frac{1}{\frac{s^2}{4\pi^2 f_n^2} + \frac{\xi}{\pi f_n} s + 1}, \end{aligned}$$

where d(s) represents the disturbances signal, f_n is the natural frequency and ξ is the damping ratio. Therefore, the spectrum, $\Gamma_M(f)$, of ER based on this second

order approximation model (see Figure 2 for an illustration of $\Gamma_M(f)$ and the dashed line in Figure 5) is given by:

$$\Gamma_M(f) = \frac{\sigma_e^2}{(1 - \frac{f^2}{f_n^2})^2 + (\frac{2\xi f}{f_n})^2},$$

where σ_e^2 is the variance of the disturbances.

(0026) $\Gamma_M(f)$ is an approximation to the spectrum $\Gamma(f)$ determined from using time series of the deviation error signal $ER(t)$.

(0027) $\Gamma_M(f)$ is maximum when $f = f_r$. The resonance frequency f_r is given by

$$f_r = f_n \sqrt{1 - \xi^2}.$$

(0028) When a control loop is mal-tuned, $0 < \xi < 1$, therefore $f_r \approx f_n$. And at $f = f_n$,

$$\Gamma_M(f_n) = \frac{\sigma_e^2}{(2\xi)^2}.$$

(0029) An estimate of σ_e^2 , the variance of disturbances, and the damping ratio ξ , is obtained by combining this last equation with the following one:

$$\Gamma_M(f_n + \varepsilon \Delta f) = \frac{\sigma_e^2}{(1 - \frac{(f_n + \varepsilon \Delta f)^2}{f_n^2})^2 + (\frac{2\xi(f_n + \varepsilon \Delta f)}{f_n})^2},$$

where Δf is the frequency resolution, and $\varepsilon = 1$ or $\varepsilon = -1$, where the value of ε is chosen to minimize the error between $\Gamma_M(f)$ defined above and the spectrum $\Gamma(f)$ determined from using the time series of the deviation error signal $ER(t)$. To be able to estimate σ_e^2 and ξ using the above equations, we assume that $\Gamma_M(f) \approx \Gamma(f)$ around the resonance frequency and then substitute $\Gamma_M(f_n + \varepsilon \Delta f)$ by $\Gamma(f_n + \varepsilon \Delta f)$, and $\Gamma_M(f_n)$ by $\Gamma(f_n)$ in those equations, which leads to the following:

$$\xi = 0.5 \frac{1 - \left(\frac{f_n + \varepsilon \Delta f}{f_n} \right)^2}{\sqrt{\frac{\Gamma(f_n)}{\Gamma(f_n + \varepsilon \Delta f)} - \left(\frac{f_n + \varepsilon \Delta f}{f_n} \right)^2}} \text{ and}$$

$$\sigma_e = 2\xi\sqrt{\Gamma(f_n)}.$$

(0030) Therefore, from the above equations, the second order approximation is completely defined.

(0031) It will be appreciated that when a linear control loop is poorly tuned, it tends to oscillate at one frequency with a modulating magnitude. This is because frequencies around the resonance frequency are also amplified, and are present in the signal. The second order approximation model used here aims at capturing this phenomenon.

(0032) When backlash is present, as illustrated in Figures 8 and 9, the difference between the model and the power spectrum density will be large enough to show that it is not a tuning problem.

(0033) **Case 2, actuator or sensor non-linear behaviour:** In this case, the loop of Figure 1 is a nonlinear feedback control loop. We can use the Describing Function method to simplify the analysis of such a nonlinear feedback system, to show that:

$$ER(t) = SP(t) - PV(t) \approx \sum_{n=1}^{\infty} C_n \sin(2\pi n f_0 t + \phi_n),$$

where f_0 is the fundamental frequency and $n f_0$ are the harmonics. In this case, the spectrum ER is given by:

$$\Gamma_{ER}(f) = \sum_{n=1}^{\infty} \left(\frac{C_n}{2}\right)^2 \delta(f - n f_0),$$

where $\delta(f)$ is an impulse function which is null at all frequencies except when $f = 0$.

(0034) It follows from the expression of $\Gamma_{ER}(f)$ that the spectrum of ER is a set of impulses at a spacing of f_0 . Figure 3 illustrates this behaviour, and Figure 7 illustrates both $\Gamma(f)$ and $\Gamma_M(f)$ for an example of this behaviour.

(0035) From the above, it can be concluded that oscillations created by poor control tuning and those caused by malfunctioning actuators present distinguishable

patterns when their spectra $\Gamma_{ER}(f)$ are analysed. Furthermore, poor tuning of a control loop leads to an amplification of variability that affects the loop. This effect occurs in a relatively narrow frequency range, at the so-called resonant frequency, and, to a lesser extent, at the surrounding frequencies. In a poorly tuned loop, the control error would typically exhibit oscillations in the time domain at a given frequency with varying amplitude.

(0036) It has been shown that, in the process industry, the dynamic of a closed loop system could be generally approximated by a second order model, i.e., where the input and output are related through second order differential equations. A second order model of the process is completely defined by three parameters: the gain, the damping factor, and the natural frequency. Poor tuning results in a low value of the damping coefficient and a large amplification around the resonant frequency close to the natural frequency.

(0037) If we assume that the disturbances affecting the process are reasonably well distributed in frequencies, the power spectral density of the control error will be proportional to the square of the module of the transfer function. The transfer function, a second order approximation of the process, can then be estimated from the value of the power spectral density around the resonant frequency.

(0038) The method developed is based on the evaluation of how well the power spectral density curve of the control error can be modeled using a second order approximation of the process transfer function.

(0039) As illustrated in Figure 11, the method involves the following steps:

- Calculate the power spectral density $\Gamma(f)$ of the control error using the time series of the error signal $ER(t)$.
- Determine the frequency at which the power spectral density is maximum
- Derive the second order model, and generate the analytical approximation of the power spectral density $\Gamma_M(f)$.
- Establish if the model based estimation of the spectral density of the control error is a valid approximation of the actual one, in which case malfunctioning is due to inadequate tuning.

(0040) The following ratio is used to compare $\Gamma_M(f)$ with $\Gamma(f)$

$$R(\%) = 100 \frac{\sum_{k=n_0}^n (\Gamma(k\Delta f) - \Gamma_M(k\Delta f))}{\sum_{k=n_0}^n \Gamma(k\Delta f)},$$

where Δf is the frequency resolution, n_0 is chosen as to exclude frequencies close to zero where the power spectrum density is likely to be poorly estimated. A threshold of $n_0 \approx 5$ is often used which means that the first n_0 value of the power spectral density is not used in the comparison with the model based estimation. n is the dimension of $\Gamma(f)$. $R(\%)$ close to zero indicates that excess variation is due to frequencies around the resonant frequency caused by tuning problems. An $R(\%) \gg 0$ indicates that other frequencies, possibly harmonics are contributing to excess variation. $R(\%)$ is compared to a threshold in the range of (10 to 15%) to decide which phenomenon is prevailing.

(0041) Actuator problems, such as stiction, typically lead to harmonic oscillations of the type illustrated in Figure 3. The spectrum of the output response for a pressure control loop exhibiting oscillations at the harmonic frequencies is illustrated in Figure 7. A comparison between $\Gamma_M(f)$ and $\Gamma(f)$ will yield in this case an $R(\%) \gg 0$, indicating that the oscillation is due to malfunctioning equipment.

(0042) Similarly, other non-linear behaviour, due for example to backlash, may yield a power spectrum such as that in Figure 9.

(0043) In the preferred embodiment, the invention is implemented by apparatus as illustrated in Figure 10. The error signal ER is recorded over time to provide the time series signal ER(t). This apparatus may also be provided by software running in computerized control loop monitoring equipment.